

Client: Bang On The Wall Band

Test Equipment

Equipment Used: Seaward Europa Plus Serial Number: V09-0179
Tested By: John Alexander Test Date: 16/11/09
This certificate is not valid after: 16/11/10 and equipment must be retested

Asset ID	Description	Location	Class	Insulation Resistance M Ohm	Earth Continuity Ohm	Visual inspection	Overall Pass Y/N?
1	MACKIE SR1521Z	Mobile		>99.99	0.08	Pass	Pass
2	IEC LEAD	Mobile		>99.99	0.06	Pass	Pass
3	IEC LEAD	Mobile		>99.99	0.06	Pass	Pass
4	MACKIE SR1512Z	Mobile		42.65	0.09	Pass	Pass
5	IEC LEAD	Mobile		>99.99	0.04	Pass	Pass
6	VIRTUALIZER	Mobile		>99.99	0.05	Pass	Pass
7	BEHRINGER PSU	Mobile		>99.99		Pass	Pass
8	EURORACK MX 2004A	Mobile		>99.99		Pass	Pass
9	SINGLE 10M EXTENSION	Mobile		>99.99	0.15	Pass	Pass
10	2 WAY EXTENSION	Mobile		>99.99	0.09	Pass	Pass
11	IEC LEAD	Mobile		>99.99	0.04	Pass	Pass
12	IEC LEAD	Mobile		>99.99	0.05	Pass	Pass
43	PROAMPLIFIERS VSG65	Mobile		>99.99	0.08	Pass	Pass
44	IEC LEAD	Mobile		>99.99	0.06	Pass	Pass
45	IEC LEAD	Mobile		>99.99	0.04	Pass	Pass
46	RMS AC40 AMP	Mobile		>99.99	0.07	Pass	Pass
47	IEC LEAD	Mobile		>99.99	0.05	Pass	Pass
48	4 WAY	Mobile		>99.99		Pass	Pass
49	PHONIC POWER POD7	Mobile		>99.99	0.09	Pass	Pass
50	IEC LEAD	Mobile		>99.99	0.06	Pass	Pass
51	MAJ ELECTRONIC PA	Mobile		>99.99	0.07	Pass	Pass
53	SMOKE MACHINE	Mobile		36.51	0.06	Pass	Pass
54	ROLAND BASS CUBE 30	Mobile		>99.99	0.09	Pass	Pass
55	ROLAND DB-500 BASS	Mobile		>99.99	0.08	Pass	Pass