

Client: BANG ON THE WALL BAND

Original PAT Certificate

Test Equipment

Equipment Used: Seaward Europa Plus Serial Number: V09-0179
 Tested By: John Alexander Test Date: 17/11/2010
 This certificate is not valid after: 17/11/2011 and equipment must be retested

Asset ID	Description	Location	Class	Visual inspection	Insulation Resistance MΩ	Earth Continuity Ω	Test Result
1	IEC LEAD	MOBILE	I	PASS	>99.99	0.05	PASS
2	PROAMP VSQ65	MOBILE	I	PASS	>99.99	0.09	PASS
3	RMS SAC40	MOBILE	I	PASS	>99.99	0.08	PASS
4	FRESHMAN AC30R	MOBILE	I	PASS	>99.99	0.06	PASS
5	BOSE 802C	MOBILE	I	PASS	>99.99	0.13	PASS
6	CROWN XLS402	MOBILE	I	PASS	>99.99	0.09	PASS
7	ROLAND DB500	MOBILE	I	PASS	>99.99	0.08	PASS
8	6M EXT REEL	MOBILE	I	PASS	>99.99	0.2	PASS
9	4 WAY EXT	MOBILE	I	PASS	>99.99	<0.04	PASS
10	IEC LEAD	MOBILE	I	PASS	>99.99	0.06	PASS
11	2 WAY EXT	MOBILE	I	PASS	>99.99	0.13	PASS
12	IEC LEAD	MOBILE	I	PASS	>99.99	0.06	PASS
13	IEC LEADIEC LEAD	MOBILE	I	PASS	>99.99	0.05	PASS
14	MACKIE SR1521Z	MOBILE	I	PASS	16.76	0.07	PASS
15	MACKIE SR1521Z	MOBILE	I	PASS	42.3	0.09	PASS
16	IEC LEAD	MOBILE	I	PASS	>99.99	0.05	PASS
17	IEC LEAD	MOBILE	I	PASS	>99.99	0.05	PASS
18	IEC LEAD	MOBILE	I	PASS	>99.99	0.04	PASS
19	IEC LEAD	MOBILE	I	PASS	>99.99	0.05	PASS
20	2 WAY EXT	MOBILE	I	PASS	>99.99	0.07	PASS
21	1 WAY EXT	MOBILE	I	PASS	>99.99	0.12	PASS
22	BEHRINGER PSU	MOBILE	II	PASS	>99.99		PASS
23	BEHRINGER DESK	MOBILE	II	PASS	>99.99		PASS
24	IEC LEAD	MOBILE	I	PASS	>99.99	0.04	PASS
25	BEHRINGER VIRTUALIZER	MOBILE	I	PASS	>99.99	0.06	PASS